



Halspan Smoke and Acoustic Perimeter Seal



Halspan Smoke and Acoustic Perimeter Seal provides excellent protection against cold smoke by forming an uninterrupted seal between the door frame and door leaf. It is simple to fit, with strong high tack double sided self adhesive strip. The seal has 3 separate air pockets which provide a very effective acoustic performance.



Permitted for use with 30, 60, 90 & 120 Minute Doors in Timber Frames

Tested in Accordance with:

EN 1634-1*

*See notes section overleaf on smoke control and further considerations for other relevant test standards



Product Codes & Specifications

Master Product Code: SLS-ACS1

Halspan Smoke & Acoustic Perimeter Seal

Colour	Product Codes (10mm x 10mm)*		
	2100mm length	2500mm length	3000mm length
● Brown	SLS-ACS1-21BR	SLS-ACS1-25BR	SLS-ACS1-30BR
● Black	SLS-ACS1-21BK	SLS-ACS1-25BK	SLS-ACS1-30BK
○ White	SLS-ACS1-21WH	SLS-ACS1-25WH	SLS-ACS1-30WH

*Previous product codes: SLS-ACS1-BLK and SLS-AFS-BLK





Smoke

A Note on Smoke Control

(from BS 8214: 2016)

The test standards for determining smoke leakage are BS 476-31.1 and BS EN 1634-3. Smoke leakage is essentially the transfer of airborne particles of the products of combustion, and sealing systems are used to restrict this air flow. Seals are used to fill the gaps between the door leaf and the frame. As such, they can have an adverse effect on the operating forces required to use the door if not carefully fitted. Removal of seals to accommodate door hardware increases the leakage rate. Seals that fit in the centre thickness of the door are generally subjected to friction effects detrimental to the durability of the seal and the easy use of the door. Seals applied to the face of the doorstop are unlikely to have a noticeably adverse effect on the forces required to open the door. Doorstop-mounted seals might prevent the door from latching or closing if incorrectly fitted, or when incorporated within a door rebate that has not been designed to accommodate such seals.

Fire doors that are required by the appropriate building regulations to restrict the flow of ambient temperature smoke, identified by the suffix S, e.g. FD30S, FD 30S (BS 476-31) or the suffix Sa, e.g. E 30Sa (BS EN 1634-3), should be fitted with smoke seals. When installed, the threshold gap should, where practicable, be sealed by a (flexible edge) or automatic drop seal, either with a leakage rate not exceeding 3 m³/h per metre at 25 Pa when tested to BS 476-31.1 or BS 1634-3, or just contacting the floor, giving an even contact with the floor but not exhibiting significant increased frictional forces that could interfere with the closing action of the door. Where this is impracticable, the threshold gap should not exceed 3 mm at any point.

Halspan strongly recommend the use of our SLS-DRP range of automatic drop seals to ensure compliance on smoke rated doorsets.



General Notes

Further Considerations

Note that there is other guidance available, including BS 9999:2017 - Code of practice for fire safety in the design, management and use of buildings, which may impose different or additional requirements, such as consideration of the gap between door leaf and threshold.

Halspan intumescent seals and smoke seals have undertaken extensive testing over many years and have been proven to perform against the toughest test standards in the most onerous of doorset designs. Care must be taken to ensure that these seals are used in the correct manner, in accordance with certification data such as Field of Application Reports and primary test evidence.

Further industry guidance can also be found in the following publications:

- BS 8214:2016: Timber-based fire door assemblies - Code of practice
- BS 9999:2017: Fire safety in the design, management and use of buildings – Code of practice
- ASDMA - Guidance and Recommendations for the Coordination of Bespoke Doorsets
- ASDMA - Best Practice Guide to Timber Fire Doors

Supporting Certification & Test Data

Certification - Fire

- Warringtonfire Halspan Optima 30 Field of Application Report Chilt/A01204
- Warringtonfire Halspan Optima 60 Field of Application Report Chilt/A01205
- Warringtonfire Halspan Prima 30 Field of Application Report FEA/F97174
- Warringtonfire Halspan Prima 60 Field of Application Report FEA/F96103
- Warringtonfire Halspan 90 Field of Application Report Chilt/A05151
- Warringtonfire Halspan 120 Field of Application Report BMT/CNA/F15082
- Warringtonfire Halspan XT/IT 30 Field of Application Report Chilt/A13242
- Warringtonfire Halspan XT/IT 60 Field of Application Report Chilt/A13227
- IFC Halspan Optima 30 Field of Application Report PAR/10341/01
- IFC Halspan Optima 60 Field of Application Report PAR/10341/02
- IFC Halspan Prima 30 Field of Application Report IFCA/06166
- IFC Halspan Prima 60 Field of Application Report IFCA/06167
- IFC Halspan 90 Field of Application Report - PAR/10513/01
- IFC Halspan 120 Field of Application Report - PAR/10513/02
- IFC Halspan XT/IT 30 Field of Application Report - PAR/20910/01
- IFC Halspan XT/IT 60 Field of Application Report PAR/21548/01

Smoke Test Data

- WYC552501, WYC552503, WYC552504 & WYC552505
- WYC531315/03, 04, 07 & 08
- WYC551410
- WYC551411
- WYC553325

The information in this datasheet is correct at time of going to press. However our designs, specifications and certifications may change in the interest of product development following publication. If you would like to make a query about any of the details in this document, please contact Halspan via our website, or call our office in the UK on +44 (0)3300 563836.

