

Certificate of Registration

Certificate Number 014

Placed on the Market under the Name of

**Halspan Limited
Regent House
Regent Centre
Linlithgow
West Lothian
EH49 7HU
UNITED KINGDOM**

and produced in the manufacturing plants

Site G8
(Licence No. E001474)

Site G12
(Licence No. E002328)


This certificate attests that all provisions have been met concerning the BM TRADA requirements of the scheme:

Q-Mark Timber Fire Door Manufacture

Date of Initial Certification: **04/12/1998**

Date of Last Issue: **26/06/2025**

Date of Expiry: **02/12/2025**



Jon Lessimore (Divisional Director)
For and on behalf of Element

Scope of Certification

Primary Field of Application (FoA) Reports (owned by this certified company)

Either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely

Type	FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Integrity Period	FoA Standard
Fire	Chilt/A01204	H	Halspan Limited	Optima 30 Part 1 Timber (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A01204	G	Halspan Limited	Optima 30 Part 2 Steel (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A01205	J	Halspan Limited	Optima 60 Part 1 Timber (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A01205	J	Halspan Limited	Optima 60 Part 2 Steel (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F97174	J	Halspan Limited	Prima 30 Part 1 Timber (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F97174	J	Halspan Limited	Prima 30 Part 2 Steel and Aluminium Frames (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F97174	J	Halspan Limited	Prima 30 Part 3 Bond Up (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F97174	J	Halspan Limited	Prima 30 Part 4 PVC (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F97174	J	Halspan Limited	Prima 30 Part 5 Prima Plus (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	WF523362	-	Halspan Limited	Prima 30 Range of Doorsets in Timber Based Doors Frames with Ambient Temperature Smoke Control (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	-	-	-			BS 476 Pt31.1
Fire	FEA/F96103	Q	Halspan Limited	Prima 60 Part 1 Timber (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F96103	P	Halspan Limited	Prima 60 Part 2 Steel (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F96103	P	Halspan Limited	Prima 60 Part 3 Bond Up (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F96103	P	Halspan Limited	Prima 60 Part 4 PVC (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	FEA/F96103	P	Halspan Limited	Prima 60 Part 5 Prima Plus (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	WF532767	A	Halspan Limited	Prima 60 Range of Doorsets in Timber Based Doors Frames with Ambient Temperature Smoke Control (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	-	-	-			BS 476 Pt31.1
Fire	Chilt/A12061	B	Halspan Limited	Halspan 30 Part 1 Timber (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A12061	B	Halspan Limited	Halspan 30 Part 2 Steel (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A12064	C	Halspan Limited	Halspan 60 Part 1 Timber (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A12064	C	Halspan Limited	Halspan 60 Part 2 Steel (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A05151	L	Halspan Limited	Halspan 90 (Glazed or Unglazed)	90min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	WF389581	B	Halspan Limited	Halspan 90 Prima Plus (Glazed or Unglazed)	90min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	BMT/CNA/F15082	H	Halspan Limited	Halspan 120 (Glazed or Unglazed)	120min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	WF389580	C	Halspan Limited	Halspan 120 Prima Plus (Glazed or Unglazed)	120min	BS 476 Pt22
Smoke	N/A	-	-			N/A
Fire	Chilt/A13242	F	Halspan Limited	Halspan XT30 and IT30 30 minute fire resisting doorsets (Glazed or Unglazed)	30min	BS 476 Pt22
Smoke	N/A	-	-			N/A

Fire	Chilt/A13227	E	Halspan Limited	Halspan XT60, IT60, XT60 Head Rail and XT60R 60 minute fire resisting doorsets (Glazed or Unglazed)	60min	BS 476 Pt22
Smoke	N/A	-	-			N/A

Primary Field of Application (FoA) Reports (owned by and cascaded by a System Supplier)

The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Type	FoA Report	System Supplier owner of Assessment Report	Doorset Description	Integrity Period	FoA Standard
Fire	N/A	-	-	-	-
Smoke	N/A	-			-

Test Reports

Test reports cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Type	Test Report	Owner of Test Report	Doorset Description	Integrity Period	Test Standard
Fire only	N/A	-	-	-	-